

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7165-694:215 Page 1 of 1

**CATEGORY:** Control Unit (Non High-Rise)

**LISTEE:** Fire Control Instruments, \*16 Southwest Park, Westwood MA 02090  
Contact: Anthony J. Shalna (781) 471-3000 FAX (781) 471-3099

**DESIGN:** Model FC-10C fire alarm control unit. Power-limited; non-coded, local, remote station and central station service; manual, automatic, waterflow and sprinkler supervisory service. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

FC-10C	Control Unit
CAC-10F	Class A Connector
PRT-24	Printer Interface Module
NAC-REM	Bell/Relay Expander Module
XRM-24	Transformer
LED-10IM	Annunciator Interface Module
DP-5210UD	Front Cover

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical ratings, and UL Inc. Label

**APPROVAL:** Listed as a fire alarm control unit for use with separately listed electrically compatible initiating and indicating devices.

This control unit can generate the temporal code pattern fire alarm signal as required per NFPA 72, 1999 Edition. Refer to manufacturer's Installation Manual for details.

**NOTE:** For **Fire Alarm Verification Feature**, the maximum Retard/Rest/Restart period shall not exceed 30 seconds.

**XLF:** 7165-0075:177

\*Rev. 02-05-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 21, 2004**

*Listing Expires **June 30, 2005***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager